



Certificate No.:

0845 – CPD–232.1490

EC-CERTIFICATE OF CONFORMITY

Issued by Danish Institute of Fire and Security Technology. Notified body No. 0845

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction products

GFE detector type GFE-SH-2
GFE detector type GFE-SH-2L
GFE detector type GFE-SH-4-12
GFE detector type GFE-SH-4-24

Multi sensor detector smoke/heat
Multi sensor detector smoke/heat with output for LED
Multi sensor detector smoke/heat with 12V relay
Multi sensor detector smoke/heat with 24V relay

for applications related to automatic fire alarm systems

placed on the market by

Global Fire Equipment Ltd.
Urb. Vale da Amoreia, Lt 16 & 17,
Porta A, Cave
8005-334 FARO
Portugal

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body Danish Institute of Fire and Security Technology (*Dansk Brand- og sikringsteknisk Institut*) has performed the initial type-testing for the relevant characteristics of the products, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all the provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN54-5:2000


Fire detection and fire alarm systems – Part 5:
Heat detectors – Point detectors

were applied and that the products fulfils all the prescribed requirements.

The attached 3 annexes forms part of this certificate.

This certificate was first issued on **2005-07-27** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC it selves are not modified significantly.


Technical Officer


Head of section